

**PROFORMA REGARDING SAFE DRINKING WATER AND
SAINITARY CONDITION CERTIFICATE**

No. 4600.

Date : 26/06/2025

It is certified that an inspection team headed by

[Signature] Kumar

MEDICAL OFFICER INCHARGE (Name of Officers With designation) from P.H.C CHAHANIA (Name of Department/Office) inspected the ST. JOSEPH SCHOOL CHAHANIA CHANDAULI (Name & Address of The School) on 26/06/2025 and found that the ST. JOSEPH SCHOOL CHAHANIA CHANDAULI (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period of 26/06/2025 TO 25/06/2026.

Signature with Seal : _____

Name

Designation

[Signature]

[Signature]

[Signature]

प्रभारी चिकित्सा अधिकारी
प्रा० स्वा० केन्द्र
चहनियाँ

To

ST. JOSEPH SCHOOL (70287)

CHAHANIA. CHANDAULI. UP

(Name & Address of the Institution)



SBPL

SILKON BIOTECH PVT LTD

(NABL Accredited Laboratory)

CIN NO.U74999UP2017PTC091011 | GST IN : 09AAYCS2616M1ZJ

Silkon House, Lane No. 3, Maa Laxmi Nagar, Kanchanpur, D.L.W. Varanasi - 221005

Revision No.00

Format No. SBPL/QSF/11-01/00

TEST REPORT

NAME & ADDRESS OF CUSTOMERIssued to - St. Joseph School (70287)
Chahaniya, Chandauli

ULR No. TC859423000000490F

Job Order No. SBPL/DW/1001588

Report Issue Date. 19/06/2025

Water Sample Analysis Report

Type of Sample : Drinking Water
 Date of Sampling : 15/06/2025
 Test Start Date : 15/06/2025
 Test End Date : 19/06/2025
 Sampling Done By : Sample Provided by Customer
 Sampling Method : IS:3025 Part-1
 Sample Code : DW- 279
 Sample Quantity : 3 Lit
 Sampling Location : RO Water

Test Result

S. No.	Parameter	Unit	Result	Limits as per IS 10500:2012		Test Method
				Acceptable	Permissible Limits	
1.	Colour	Hazen	<5	5	15	IS:3025 (Part-04)
2.	Odour	-	Agreeable	Agreeable	Agreeable	IS:3025 (Part-05)
3.	pH	-	7.47	6.5 – 8.5	No Relaxation	IS:3025 (Part-11)
4.	Turbidity	NTU	<1	1	5	IS:3025 (Part-10)
5.	Total Dissolved Solids	mg/l	56.64	500 mg/l	2000 mg/l	IS:3025 (Part-16)
6.	Chloride (as Cl)	mg/l	16.99	250 mg/l	1000 mg/l	IS:3025 (Part-32)
7.	Total Alkalinity (as CaCO ₃)	mg/l	40.0	200 mg/l	600 mg/l	IS:3025 (Part-23)
8.	Total Hardness (as CaCO ₃)	mg/l	36.0	200 mg/l	600 mg/l	IS:3025 (Part-21)
9.	Calcium (as Ca)	mg/l	8.02	75 mg/l	200 mg/l	IS:3025 (Part-40)
10.	Magnesium (as Mg)	mg/l	3.89	30 mg/l	100 mg/l	IS:3025 (Part-46)
11.	Fluoride (as F)	mg/l	ND {LOD=0.1 mg/l}	1 mg/l	1.5 mg/l	IS:3025 (Part-60)
12.	Iron (as Fe)	mg/l	ND {LOD=0.1 mg/l}	1 mg/l	No relaxation	APHA 23 rd Edi.

Note- ND Means Not Detected

A
Checked By

END OF REPORT

Note:-

- The results given above are related to the tested sample, as received & mentioned parameters. The customer asked for the above tests only.
- The Result Tested as per Requirement of Customer.
- This Report cannot be used as evidence in the court of law and cannot be used in any media without prior permission.
- Sample will be disposed after 15 days from date of Issue of Test Report.



TC-8594

Tel - 0522-317318 | Email : silkonbiotech@gmail.com



SBPL

SILKON BIOTECH PVT LTD

(NABL Accredited Laboratory)

CIN NO.U74999UP2017PTC091011 | GST IN : 09AAYCS2616M1ZJ

Silkon House, Lane No. 3, Maa Laxmi Nagar, Kanchanpur, D.L.W. Varanasi - 221005

Revision No.00

Format No. SBPL/QSF/11-01/00

TEST REPORT

NAME & ADDRESS OF CUSTOMER

Issued to - St. Joseph School (70287)
Chahaniya, Chandauli

ULR No. TC859423000000490F

Job Order No. SBPL/DW/1001588

Report Issue Date. 19/06/2025

Biological Water Sample Analysis Report

Type of Sample : Drinking Water
Date of Sampling : 15/06/2025
Test Start Date : 15/06/2025
Test End Date : 19/06/2025
Sampling Done By : Sample Provided by Customer
Sampling Method : IS:3025 Part-1
Sample Code : DW- 279
Sample Quantity : 3 Lit
Sampling Location : RO Water

Test Result

S. No.	Parameter	Result	Limits as per IS 10500:2012	Test Method
			Requirement	
1.	E. Coli	Absent	Shall not be detectable in any 100 ml Sample	IS:1622 (1981 RA 2019)
2.	Total Coliform	Absent	Shall not be detectable in any 100 ml Sample	IS:1622 (1981 RA 2019)

Copy

Checked By

SBPL



END OF REPORT

Note:-

1. The results given above are related to the tested sample, as received & mentioned parameters. The customer asked for the above tests only.
2. The Result Tested as per Requirement of Customer.
3. This Report cannot be used as evidence in the court of law and cannot be used in part or full in any media without prior permission.
4. Sample will be disposed after 15 days from date of Issue of Test Report.



TC-8594

Tel - 0522-317318 | Email : silkonbiotech@gmail.com