

**PROFORMA REGARDING SAFE DRINKING WATER AND  
SAINITARY CONDITION CERTIFICATE**

No. 4600.

Date : 26/06/2025

It is certified that an inspection team headed by

[Signature]

MEDICAL OFFICER INCHARGE (Name of Officers With designation) from P.H.C  
CHAHANIA (Name of Department/Office) inspected the ST. JOSEPH SCHOOL  
CHAHANIA CHANDAULI (Name & Address of The School) on 26/06/2025 and  
found that the ST. JOSEPH SCHOOL CHAHANIA CHANDAULI (Name of school) has  
safe drinking water facilities for the students and members of staff of the institution and  
is maintaining the hygienic sanitation condition in the school building & the campus as  
per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period of 26/06/2025 TO 25/06/2026.

Signature with Seal : \_\_\_\_\_

Name

Designation

[Signature]  
[Signature]  
[Signature]  
प्रभारी चिकित्सा अधिकारी  
प्रा० स्वा० केन्द्र  
चहनियाँ

To

ST. JOSEPH SCHOOL (70287)

CHAHANIA. CHANDAULI. UP

(Name & Address of the Institution)



# SILKON BIOTECH PVT LTD

(NABL Accredited Laboratory)

CIN NO.U74999UP2017PTC091011 | GST IN : 09AAYCS2616M1ZJ

Silkon House, Lane No. 3, Maa Laxmi Nagar, Kanchanpur, D.L.W. Varanasi - 221005

Revision No.00

Format No. SBPL/QSF/11-01/00

## TEST REPORT

### NAME & ADDRESS OF CUSTOMER

Issued to - St. Joseph School (70287)  
Chahaniya, Chandauli

ULR No. TC859423000000490F

Job Order No. SBPL/DW/1001588

Report Issue Date. 19/06/2025

### Water Sample Analysis Report

Type of Sample : Drinking Water  
Date of Sampling : 15/06/2025  
Test Start Date : 15/06/2025  
Test End Date : 19/06/2025  
Sampling Done By : Sample Provided by Customer  
Sampling Method : IS:3025 Part-1  
Sample Code : DW- 279  
Sample Quantity : 3 Lit  
Sampling Location : RO Water

### Test Result

S. No.	Parameter	Unit	Result	Limits as per IS 10500:2012		Test Method
				Acceptable	Permissible Limits	
1.	Colour	Hazen	<5	5	15	IS:3025 (Part-04)
2.	Odour	-	Agreeable	Agreeable	Agreeable	IS:3025 (Part-05)
3.	pH	-	7.47	6.5 – 8.5	No Relaxation	IS:3025 (Part-11)
4.	Turbidity	NTU	<1	1	5	IS:3025 (Part-10)
5.	Total Dissolved Solids	mg/l	56.64	500 mg/l	2000 mg/l	IS:3025 (Part-16)
6.	Chloride (as Cl)	mg/l	16.99	250 mg/l	1000 mg/l	IS:3025 (Part-32)
7.	Total Alkalinity (as CaCO <sub>3</sub> )	mg/l	40.0	200 mg/l	600 mg/l	IS:3025 (Part-23)
8.	Total Hardness (as CaCO <sub>3</sub> )	mg/l	36.0	200 mg/l	600 mg/l	IS:3025 (Part-21)
9.	Calcium (as Ca)	mg/l	8.02	75 mg/l	200 mg/l	IS:3025 (Part-40)
10.	Magnesium (as Mg)	mg/l	3.89	30 mg/l	100 mg/l	IS:3025 (Part-46)
11.	Fluoride (as F)	mg/l	ND {LOD=0.1 mg/l}	1 mg/l	1.5 mg/l	IS:3025 (Part-60)
12.	Iron (as Fe)	mg/l	ND {LOD=0.1 mg/l}	1 mg/l	No relaxation	APHA 23 <sup>rd</sup> Edi.

Note- ND Means Not Detected

Checked By

Authorized Signatory  
Uttam  
(Assistant Q.M.)

\*\*\*END OF REPORT\*\*\*

### Note:-

- The results given above are related to the tested sample, as received & mentioned parameters. The customer asked for the above tests only.
- The Result Tested as per Requirement of Customer.
- This Report cannot be used as evidence in the court of law and cannot be used in any media without prior permission.
- Sample will be disposed after 15 days from date of Issue of Test Report.



TC-8594

Tel - 0522-317318 | Email : silkonbiotech@gmail.com





SBPL

# SILKON BIOTECH PVT LTD

(NABL Accredited Laboratory)

CIN NO.U74999UP2017PTC091011 | GST IN : 09AAYCS2616M1ZJ

Silkon House, Lane No. 3, Maa Laxmi Nagar, Kanchanpur, D.L.W. Varanasi - 221005

Revision No.00

Format No. SBPL/QSF/11-01/00

## TEST REPORT

**NAME & ADDRESS OF CUSTOMER**Issued to - St. Joseph School (70287)  
Chahaniya, Chandauli

ULR No. TC859423000000490F

Job Order No. SBPL/DW/1001588

Report Issue Date. 19/06/2025

**Biological Water Sample Analysis Report**

Type of Sample : Drinking Water  
Date of Sampling : 15/06/2025  
Test Start Date : 15/06/2025  
Test End Date : 19/06/2025  
Sampling Done By : Sample Provided by Customer  
Sampling Method : IS:3025 Part-1  
Sample Code : DW- 279  
Sample Quantity : 3 Lit  
Sampling Location : RO Water

**Test Result**

S. No.	Parameter	Result	Limits as per IS 10500:2012	Test Method
			Requirement	
1.	E. Coli	Absent	Shall not be detectable in any 100 ml Sample	IS:1622 (1981 RA 2019)
2.	Total Coliform	Absent	Shall not be detectable in any 100 ml Sample	IS:1622 (1981 RA 2019)

Checked By

Authorized Signatory

Vinay Kumar Rai

Varanasi

\*\*\*END OF REPORT\*\*\*

**Note:-**

1. The results given above are related to the tested sample, as received & mentioned parameters. The customer asked for the above tests only.
2. The Result Tested as per Requirement of Customer.
3. This Report cannot be used as evidence in the court of law and cannot be used in part or full in any media without prior permission.
4. Sample will be disposed after 15 days from date of Issue of Test Report.



TC-8594

Tel - 0522-317318 | Email : silkonbiotech@gmail.com

## Appendix XIII

### PROFORMA REGARDING HEALTH AND SANITARY CONDITION CERTIFICATE

No: 4108

Date: 19/02/2025

It is certified that an inspection team head by [Signature] (name of officers with designation) from PHC Chahania (name of department/office) Inspected the St. Joseph School Chahania, Chandauli. (Name & Address of the school) on 19/02/2025 and found that the St. Joseph School (Name of School) has good health facility for the student and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribe by the central/state/U.T Govt.

The above valid for Period of 19/02/2025 to 20/02/2026

Signature with Seal: [Signature]

Medical Officer Incharge  
PHC Chahaniya  
Chandauli

Name

Designation

Name & Address of office/Department : PHC, Chahaniya,

To

St. Joseph School(70287).

Chahania, Chandauli UP 232109

(name & Address of the institution)